

1

Ø 42

2

3

x4

F3.A

S: F3.A3 x3

DB: F3.A5 x5

Tc max=105°C Risk group(EN 62471:2008)=1

Fittings must only be used complete with their protection cover. Silicone protection cover of Ø 85mm and 25mm thickness.

For 42 mm diameter connection joints. Insertion depth 90 mm. Installation screws are not included. The standard electrical cable length is 150 mm. Recommended accessory: IP68 connector, ref. F3.A3 (On/Off) | F3.A5 (DALI-2).

General safety instructions: information on restrictions related to use of the light fixtures (class, IP, etc), can be found both on the fixture label and on our website at www.rovasi.com

The wiring schematics can be found on page 2 of the document.

ELECTRONIC EQUIPMENT:

S: On/Off (AC/DC, NOT looping through capable)

D: DALI-2/switchDIM/corridorFUNCTION

B: Bluetooth-Casambi [15m]

2

3

x4

Tc max=105°C Risk group(EN 62471:2008)=1

Fittings must only be used complete with their protection cover. Silicone protection cover of Ø 85mm and 25mm thickness.

2

3

x4

Tc max=105°C Risk group(EN 62471:2008)=1

Fittings must only be used complete with their protection cover. Silicone protection cover of Ø 85mm and 25mm thickness.

2

3

x4

Tc max=105°C Risk group(EN 62471:2008)=1

Fittings must only be used complete with their protection cover. Silicone protection cover of Ø 85mm and 25mm thickness.

2

3

x4

Tc max=105°C Risk group(EN 62471:2008)=1

Fittings must only be used complete with their protection cover. Silicone protection cover of Ø 85mm and 25mm thickness.

2

3

x4

Tc max=105°C Risk group(EN 62471:2008)=1

Fittings must only be used complete with their protection cover. Silicone protection cover of Ø 85mm and 25mm thickness.

2

3

x4

Tc max=105°C Risk group(EN 62471:2008)=1

Fittings must only be used complete with their protection cover. Silicone protection cover of Ø 85mm and 25mm thickness.


2

3

x4

Tc max=105°C Risk group(EN 62471:2008)=1

Fittings must only be used complete with their protection cover. Silicone protection cover of Ø 85mm and 25mm thickness.



11.9W / 350mA

711ALO.04.00-I2130
711ALO.04.00-I2131
711ALO.04.00-I2133
711ALO.04.00-I2134
711ALO.04.00-I2129
711ALO.04.00-I2132

This product contains a light source of energy efficiency class D.

LED technology and performance data are constantly changing. Current details should therefore be checked with ROVASI in order to ensure that its still the mostup to date reference. Updated data will be supplied on request. [01.07.2026]



BSI Cert ISO 9001:2015 - n°FM 39346
BSI Cert ISO 14001:2015 - n°EMS 554685

Ronda de la Font-Grossa 15
Pol. Ind. La Gavarra
08540 Centelles | Barcelona
Spain

T. +34 93 881 35 12
T. +34 93 881 37 13

info@rovasi.com
rovasi.com

Installation instructions. Mains supply wires. • Use one wire for each terminal connector only. • Use each strain relief channel for one cable only. • Installation may require advice from a qualified person. • Single lights apt for outdoor use.	Wiring guidelines • All connections must be kept as short as possible to ensure good EMI behaviour. • The cables should be run separately from the mains connections and mains cables to ensure good EMC conditions. • The LED wiring should be kept as short as possible to ensure good EMC. • The max. secondary cable length is 2m (4m circuit). Secondary switching is not permitted. • Incorrect wiring can damage LED modules. • The LED Driver has no inverse-polarity protection on the secondary side. Wrong polarity can damage led modules with no inverse-polarity protection.	Earth connection is recommended to improve following behaviour. • Electromagnetic interferences (EMI). • Transmission of mains transients to the LED output. Release of the wiring following behaviour. Press down the “push button” and remove the cable from front.
--	--	---

220-240V
0/50/60 HZ

L
N
PE

DA/N
DA/L
Isd2-1
Isd2-2 (GND)

R

SW + LED
- LED

D: DALI

D: Switch DIM
220-240V
50/60Hz

N
L
Isd2-1
Isd2-2 (GND)

R

220-240V
0/50/60 HZ

L

N

⊕

R

Isel2-1

Isel2-2 (GND)

pushBUTTON

push button

SEC

+ LED

- LED

The servicing of the light source in this luminaire should only be undertaken by the manufacturer or his service agent or a similar qualified person.

The servicing of the driver in this luminaire should only be undertaken by the manufacturer or his service agent or a similar qualified person.